certif Certificado

CERTIFICATE OF CONSTANCY OF PERFORMANCE

1328–CPR–0895

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

FIRE DETECTION AND FIRE ALARM SYSTEMS:

POWER SUPPLY EQUIPMENT

Intended use	References
Fire Safety	FPS-725A, FPS-725B, FPS-745A, FPS-745B

Technical characteristics	
FPS-725A, FPS-725B,	Output: 2,5 A DC
FPS-745A, FPS-745B	Output: 4,5 A DC

placed on the market under the name or trade mark of

PARADOX HELLAS S.A. – OIKONOMIDIS P. SECURITY SYSTEMS S.A.

3 Korinthou str., 14451, Metamorfosi, Attiki, Greece

and produced in the manufacturing plant

PARADOX HELLAS S.A. – OIKONOMIDIS P. SECURITY SYSTEMS S.A.

69th klm of N.R. Athens-Lamia, 32009, Vrises Ritsonas, Avlida, Greece

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-4:1997, EN 54-4:1997/AC:1999, EN 54-4:1997/A1:2002, EN 54-4:1997/A2:2006

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure **the constancy of performance of the construction product**.

This certificate was first issued on 2023-05-19 and will remain valid as long as neither the harmonised standard, the construction product, the assessment and verification of constancy of performance methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Almada, 2023-05-19

Francisco Barroca
General Manager

IPAC acreditação
C0004
ISO/IEC 17065
Produtos

Certif – Associação para a Certificação
Rua José Afonso, 9 E – 2810-237 Almada – Portugal – Tel.: 351. 21 258 69 40 – E-mail: mail@certif.pt