



# Certificate of Continued Compliance 222350012/AA/00



Issued	06-10-2022	Replaces	
Expiry date	06-10-2026	Page	1 / 4

In compliance with the procedure specified in the **Alarm Components Scheme**, Kiwa FSS products declares that the stated alarm equipment complies with the technical standards and specifications as listed in Annex 2 of this certificate. This certificate relates to an ISO/IEC 17067 scheme type 5 registration including biennial factory inspection and yearly market surveillance.

Product description:	Intrusion detector
Trademark:	OPTEX
Type designation:	FLX-A-DAM-X5
Software:	1069.3
Variants:	See Annex 3

Placed on the market under the name or trademark of:

Name of the manufacturer:	Optex Co. , LTD.
Address:	Ogoto Shiga 5-8-12
City:	520-0101 Otsu City
Country:	JP

This certificate is granted to:

Name of the certificate holder:	Optex Co. , LTD.
Address:	Ogoto Shiga 5-8-12
City:	520-0101 Otsu City
Country:	JP

Ron Scheepers  
Managing director

*This certificate has THREE Annexes.*

Telefication B.V.  
Kiwa FSS Products  
Wilmersdorf 50  
Postbus 137  
7300 AC Apeldoorn  
The Netherlands

<https://www.kiwa.com/nl/en/specials/fire-safety-and-security>



**Remarks and observations**

The following conditions are applicable:

Security grade: 3

Environmental class: II

Equipment class: Fixed

Options CW-G3, wall and ceiling mount brackets not included in certificate.

This equipment can be applied in EN 50131-1 compliant systems up to and including security grade 3.

Factory location:

OPTEX(DONGGUAN) CO.,LTD.

No.2, Jufu Road, Banhu, Huanginang Town,

GuangDong, 523752,

DongGuan City,

P.R.China

Product inspection location:

Nippon Express Nederland

Industrieweg15

Voorschoten

The Netherlands

**Documentation lodged for this Certificate of Continued Compliance**

Test Reports:

- Telefication B.V.: P000117869-001-Ver. 1.00, 20 September 2022

Product Documentation:

- Assembly drawings
- Bill of material / Parts list
- Electronic schematics
- Manual
- Internal / external photos
- Label and label placement

**Technical Standards and Specifications**

The product shows no non-compliances with:

EN 50131-2-4	August, 2020
--------------	--------------

**Applied Standards**

EN 50130-5	June, 2011
EN 50130-4+A1	October, 2014
EN 50131-1+A1+A2+A3	June, 2020

**The product as described in this certificate includes the following type designations**

- Product description: Intrusion detector  
- Trademark: OPTEX  
- Type designation: FLX-A-DAM-X5  
- Hardware version: 0  
- Software version: 1069.3

- Product description: Intrusion detector  
- Trademark: OPTEX  
- Type designation: FLX-A-DAM-X8  
- Hardware version: 0  
- Software version: 1069.3