



CERTIFICATE No. 00049/101/1/2021

on June 4th, 2021

Certification body of EVPÚ a.s. confirms the compliance of the products with requirements of undermentioned standards.

Product: **Single loop analogue addressable fire control panel**

Type: **SmartX 132 HO,**

Derived variants: **SmartX 116 HO, SmartX 132 AP, SmartX 116 AP**

Specification: **230 VAC, 50-60 Hz, 1 A, Class I**

Client/Manufacturer: **PARADOX HELLAS S.A. - OIKONOMIDIS P. SECURITY SYSTEMS S.A.**
3 Korinthou str., 14451 Metamorfosi, Attiki, Greece

Manufacturing facilities: **PARADOX HELLAS S.A. - OIKONOMIDIS P. SECURITY SYSTEMS S.A.**
69th Klm of N.R.Athens – Lamia, 32009 Vrises Ritsonas, Avlida, Greece

Standards: **EN IEC 62368-1: 2020 + A11: 2020**
EN 55032: 2015 + A1: 2020 + A11: 2020
EN IEC 61000-3-2: 2019
EN 61000-3-3: 2013 + A1: 2019
EN 50130-4: 2011 + A1: 2014

Results of tests of mentioned products are summarized in Final report on assessment No. **0-0172/21/C** of June 4th, 2021.

Used standards are harmonized with directives of the European parliament and of the Council 2014/35/EU transposed into Slovak government decree No. 148/2016 Z. z. and 2014/30/EU transposed into Slovak government decree No. 127/2016 Z. z.

Validity of certificate
is limited for the period
from: **June 4th, 2021**
until: **June 3rd, 2024**




Dušan Novotný

Any significant changes in the design or construction of the products or amendments of the technical decrees reference above may render this Certificate invalid. The product liability rests with the manufacturer or his representative.

054058

EVPÚ a.s., Trenčianska 19, 018 51 Nová Dubnica, Slovak republic, www.evpu.sk