



Notified Body No. 0370

# CERTIFICATE



No. **0370-CPR-2112**

## CERTIFICATE OF CONSTANCY OF PERFORMANCE

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

### FIRE DETECTION AND FIRE ALARM SYSTEM. PART 11: MANUAL CALL POINTS

MODELS: **PM20 & PM20L**

Place on the market under the name of:

**DOWER SECURITY, S.L.**

C/ PARÍS Nº 1-7  
08191 RUBÍ (BARCELONA)

And produced in the manufacturing plant:

C/ PARÍS Nº 1-7  
08191 RUBÍ (BARCELONA)

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard

**EN 54-11:2001, EN 54-11:2001/A1:2005**

under system 1 are applied and that **the product fulfils all the prescribed requirements set out above.**

This certificate was first issued on 22<sup>nd</sup> May 2015 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly. It is confirmed on 6<sup>th</sup> June 2019.

**The monitoring assessment will be done before May 2020**

Bellaterra, 6<sup>th</sup> June 2019

  
Applus<sup>+</sup>  
LGA Technological Center, S.A.

Xavier Ruiz Peña  
Managing Director, Product Conformity B.U.



*This document is not valid without its technical annex, whose number coincides with the number of certificate*

## TECHNICAL ANNEX 0370-CPR-2112

# CERTIFICATE OF CONSTANCY OF PERFORMANCE

Annexes according to **EN 54-11:2001, EN 54-11:2001/A1:2005**

ESSENTIAL CHARACTERISTICS	CLAUSES IN THIS EUROPEAN STANDARD	MANDATED LEVEL(S) OR CLASS(ES)
Marking and data	4.2	PASS
Normal condition	4.3.1	PASS
Alarm condition	4.3.2	PASS
Indicators for alarm condition	4.4	PASS
Reset facility	4.5	PASS
Test facility	4.6	PASS
Shape, dimensions and colours	4.7.2	PASS
Symbols and lettering	4.7.3	PASS
Protection against accidental operation	4.7.4	PASS
Environment category	4.7.5	PASS
Additional requirements for software controlled manual call points	4.8	NA
Operational performance test	5.2	PASS
Function test	5.3	PASS
Test facility test (operational)	5.4	PASS
Reliability test (endurance)	5.5	PASS
Variation of supply parameters	5.6	PASS
Dry heat (operational)	5.7	PASS
Dry heat (endurance)	5.8	NA
Cold (operational)	5.9	PASS
Damp heat, cyclic (operational)	5.10	PASS
Damp heat, cyclic (endurance)	5.11	NA
Damp heat, steady state (endurance)	5.12	PASS
SO2 corrosion (endurance)	5.13	PASS
Shock (operational)	5.14	PASS
Impact (operational)	5.15	PASS
Vibration, sinusoidal (operational)	5.16	PASS
Vibration, sinusoidal (endurance)	5.17	PASS
Electromagnetic compatibility (EMC) (operational)	5.18	PASS
Enclosure protection	5.19	NA

PASS; NPD = No Performance Determined, NA = Not Apply

