



ENGINEERING SAFETY CONSULTANTS

The Global Provider of Functional Safety Expertise and Technical Consultancy

Certificate of Conformity to IEC 61508 Safety Integrity Level (SIL) 2

Functional Safety of Safety-Related Programmable Electronic Systems

The **Hochiki Europe (UK) Ltd, CHQ-PCM(SCI), CHQ-PCM/DIN(SCI), CHQ-DIM2(SCI), CHQ-DIM2/DIN(SCI), CHQ-DRC2(SCI) and CHQ-DRC2/DIN(SCI)** for use in fire detection and alarm systems has been assessed and is considered capable for use in a low demand Safety Function up to SIL 2, with regard to random failure rates and architectural constraints.

The assessment was based on the assumptions, data provided, and recommendations given in:

- **ESC Ltd Report: D134_SV001 rev. 4.**

The products were assessed against the following failure modes:

- Failure to send valid signal to controller when end device impedance is between 200 Ω and 1000 Ω ;
- Failure to initiate a valid output command when requested.

The products assessed include the following results:

- SIL 2 SIF suitable – CHQ-PCM(SCI), CHQ-PCM/DIN(SCI), CHQ-DRC2(SCI) and CHQ-DRC2/DIN(SCI) with simplex input and/or duplex output module configuration;
- SIL 2 SIF suitable – CHQ-PCM(SCI), CHQ-PCM/DIN(SCI), CHQ-DRC2(SCI) and CHQ-DRC2/DIN(SCI) with only input;
- SIL 1 SIF suitable – CHQ-PCM(SCI), CHQ-PCM/DIN(SCI), CHQ-DRC2(SCI) and CHQ-DRC2/DIN(SCI) simplex output module configuration;
- SIL 2 SIF suitable – CHQ-PCM(SCI), CHQ-PCM/DIN(SCI), CHQ-DRC2(SCI) and CHQ-DRC2/DIN(SCI) with duplex output module configuration;
- SIL 2 SIF suitable – CHQ-DIM2(SCI) and CHQ-DIM2/DIN (SCI).

The assessments were carried out to determine compliance with IEC 61508 with regards to:

- Random Hardware Failures (Predicted PFD $<1.0E-03$ (assuming a 1-year proof test and average repair time of 168 hrs));
- Architectural Constraints:
 - Input Block, Type A, SFF $>90\%$, $<99\%$;
 - Main Processor Block, Type B, SFF $>90\%$, $<99\%$;
 - Simplex Output Block, Type A, SFF $>0\%$, $<60\%$.

Managing Director: Kenneth G L Simpson

Member of the IEC61508 committee

Assessment Date: January 2015

Renewal Date: December 2018, valid to December 2020

Certificate: D134_CT001 rev. 5

ENGINEERING SAFETY CONSULTANTS LTD
is ISO9001-certified by Global Group, itself a
UKAS-accredited ISO9001 certification
body

Reg: 12Q12086

ENGINEERING SAFETY CONSULTANTS LTD

Tuition House

27-37 St George's Road Wimbledon London SW19 4EU UK

Telephone/Fax: +44 (0)20 8542 2807

E-Mail: info@esc.uk.net Web: www.esc.uk.net

Registered in England and Wales: 7006868

Registered Office: 27-37 St George's Road Wimbledon London SW19 4EU